

# Certificate of Compliance

Certificate Number 20041223 MH15389  
Report Reference MH15389, 2004 July 20  
Issue Date 2004 December 23

Page 1 of 1



*Issued to:* Healy Systems Inc

17 Hampshire Dr  
Hudson, NH 03051 USA

*This is to certify that  
representative samples of*

Vapor Processing System  
Model 9961 Clean Air Separator


*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* UL87, Tenth Edition, UL142, Seventh Edition, UL567, Eighth Edition,  
UL842, Eighth Edition, UL60079-1 Clauses 15.1.2 and 15.1.3  
NFPA 30A, Chapter Ten


*Additional Information:* System efficiency has not been evaluated by UL.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:

 with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by:   
Robert A. Deadman / Staff Engineer  
Underwriters Laboratories Inc.

Reviewed by:   
Paul T. Kelly / Business Unit Manager  
Underwriters Laboratories Inc.